



LIGHTNING IMPULSE WITHSTAND VOLTAGE 1470 kV
 POWER-FREQUENCY WITHSTAND VOLTAGE, WET 590 kV
 CRITICAL IMPULSE FLASHOVER, POSITIVE 1610 kV
 MAX. RIV AT 1000 kHz 1000 μ V
 LOW-FREQUENCY TEST VOLTAGE (RIV) 220 kV
 CREEPAGE DISTANCE - NOMINAL 273 in 6930 mm
 - MINIMUM 265 in 6722 mm
 MINIMUM FAILING LOAD - BENDING 1170 lb 5.2 kN
 - TENSILE 20000 lb 89 kN
 - COMPRESSION 60000 lb 269 kN
 - TORSION 40000 in-lb 4.5 kNm
 MAX. ANGULAR DEVIATION OF FIXING HOLES 1°
 TESTING ACC. TO ANSI C29.1
 MECHANICAL ROUTINE TEST: BENDING 4 x 50%
 FIXING DEVICE MATERIAL: MALLEABLE CAST IRON,
 HOT DIP GALVANIZED
 APPROXIMATE WEIGHT 368 lb 167 kg

4	5	WASHER		Ø17	STEEL. GALV.
4	4	HEXAG.NUT		M16	STEEL. GALV.
4	3	HEXAG.BOLT		M16x50	STEEL. GALV.
1	2	INSULATOR UNIT			
1	1	INSULATOR UNIT			
pcs	Pos.	Title	Drawing, standard	Dimension	Material

OUTDOOR POST INSULATOR
TR-371, Cat. Id: 1470 HT
TAPERED


Meister International, L.L.C.
 Tel: 513-923-2712 Fax: 513-923-1978
 sales@meisterintl.com www.meisterintl.com